WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45613
Permit No.
Basin 222

NOTICE OF INTENT NO. 13121

1. OWNER Ms. ALICE LUKINS
MAILING ADDRESS P.O. BOX 2140
MESQUITE NV 89024

ADDRESS AT WELL LOCATION 471 W. MESQUITE BLVD

2. LOCATION SE ¼ NE ¼ Sec. 17 T. 13 N(S) R. 71 E. CLARK County
PERMIT NO. M0-2472 (Issued by Water Resources) 670-230-007 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE MW-2
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| FILL | | 0 | 2 | 2 |
| WELL GRADED GRAVEL | | 2 | 3 | 1 |
| LEAN CLAY | | 3 | 5 | 2 |
| WELL GRADED GRAVEL | | 5 | 6 | 1 |
| SILTY SAND | | 6 | 19 | 13 |

RECEIVED
AUG 08 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started JULY 25, 1994
Date completed JULY 25, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 19 Feet Depth Cased 19 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 8 Inches | 0 Feet | 19 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2.375 | 0.64 | 0.154 | 0 | 19 |
| | | | | |

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 4 feet to 19 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-2'/2-3' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 3 feet to 19 feet

9. WATER LEVEL
Static water level 15 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Address 4670 SO. POLARIS AVE (Contractor)
LAS VEGAS NV 89103 (Contractor)
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed (By driller performing actual drilling on site or contractor)
Date AUG 2 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627