WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45618
Permit No.
Basin 163

NOTICE OF INTENT NO. 13391

1. OWNER Donald Tuck
MAILING ADDRESS Sandy Valley
ADDRESS AT WELL LOCATION

2. LOCATION NE ¼ SE ¼ Sec. 16 T. 24 N/S R. 56 E. Clark County
PERMIT NO. (Issued by Water Resources) Parcel No. APN No. 580-120-019 Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☒ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Surface		0	64	64
W Clay Sand Gravel		64	96	32
Red Clay		96	104	8
Tan Clay		104	112	8
White Clay Rock	x	112	123	11
Sand & Gravel		123	138	15
Red Clay	x	138	172	34
Tan Clay		172	190	18

RECEIVED
SEP 20 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started July 19, 19 94
Date completed September 2, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
18	10	½

8. WELL CONSTRUCTION
Depth Drilled 190 Feet Depth Cased 190 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 Inches	0 Feet	190 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8	17lbs.	.188	0	190

Perforations:
Type perforation Torch Cut
Size perforation 1/8" wide X 12" long
From 140 feet to 190 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 190 feet

9. WATER LEVEL
Static water level 115 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Charles Nyberg (Contractor)
Address HCR 77 Box 36525 Pahrump NV. (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 7484
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1917 E.J. OATS
Signed Charles Nyberg (By driller performing actual drilling on site or contractor)
Date Sept. 14, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627