

OFFICE USE ONLY  
 Log No. 45642  
 Permit No. \_\_\_\_\_  
 Basin 162  
 1364

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_

1. OWNER Christopher Cailliet ADDRESS AT WELL LOCATION Lot 17 White St  
 MAILING ADDRESS \_\_\_\_\_  
 2. LOCATION S 1/2 1/4 NE 1/4 Sec. 8 T 20S N/S R 53 E Nye County \_\_\_\_\_  
 PERMIT NO. 36-052-05 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<del>Caliche</del> Clay		0	5	5
Caliche		5	8	3
Clay		8	43	35
Caliche		43	45	2
Clay		45	71	26
Caliche	WB	71	73	2
Clay		73	109	36
Caliche	WB	109	113	4
Clay		113	122	9
Caliche	WB	122	126	4
Clay		126	134	8
Caliche	WB	134	140	6

8. WELL CONSTRUCTION  
 Depth Drilled 140 Feet Depth Cased 140 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 0 To 140  
12 1/4 Inches Feet  
 \_\_\_\_\_ Inches Feet  
 \_\_\_\_\_ Inches Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>16.44</u>	<u>.188</u>	<u>0</u>	<u>140</u>

Perforations:  
 Type perforation Factory Sawcut  
 Size perforation 1/8 x 2  
 From 150 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 30  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 140 feet

RECEIVED

SEP 22 1994

Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 8-25, 19 94  
 Date completed 8-27, 19 94

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 46 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Great Basin Drilling Contractor  
 Address 14028 Box 80358 Contractor  
Rahway NV 89041  
 Nevada contractor's license number issued by the State Contractor's Board 30880  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642  
 Signed Thomas D...  
 By driller performing actual drilling on site or contractor  
 Date 9-13-94