

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25456  
456 Upper Colony Rd  
Wellington NV 89444

1. OWNER Tom Loyd ADDRESS AT WELL LOCATION Wellington NV  
 MAILING ADDRESS 456 Upper Colony Rd Wellington NV 89444  
 2. LOCATION SW 1/4 SW 1/4 Sec. 10 T. 11 S. R. 23 E. Lyon County  
 PERMIT NO. 10-193-01 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
overburden		0	4	4
DB Gravels		4	36	32
Brown clay		36	71	35
Course DB Sands		71	125	54
Brown sandy clays		125	175	50
Large Course DB Gravels	XXX	175	200	25
T.D. 200'				
Static 120'				
GPM 25+				

8. WELL CONSTRUCTION  
 Depth Drilled \_\_\_\_\_ Feet Depth Cased \_\_\_\_\_ Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 1/4 Inches To 0 Feet  
0 Feet 200 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6.578</u>	<u>13.03</u>	<u>.188</u>	<u>0</u>	<u>200</u>

Perforations:  
 Type perforation Mill 5/16"  
 Size perforation 3x3/8"  
 From 180 feet to 200 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 100  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 100 feet to 200 feet

9. WATER LEVEL  
 Static water level 120' feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 25+ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name A&H Pump Co. Contractor  
 Address 5551 Hwy 50 E #3 Carson City NV 89701 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 31839  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1905  
 Signed Michael J. Hest  
 By driller performing actual drilling on site or contractor  
 Date 7-25-94

Date started 7-21, 1994  
 Date completed 7-25, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>25</u>	<u>36</u>	<u>3 HRS</u>