

OFFICE USE ONLY

Log No. 43702

Permit No. 105

Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26049

1. OWNER Brad Reichardt ADDRESS AT WELL LOCATION 602 Stagecoach Rd Gardnerville, Nev
 MAILING ADDRESS P.O. Box 1439
Gardnerville, Nev. 89410

2. LOCATION T1W 1/4 21E 1/4 Sec. 25 T. 12 N/S R. 20 E. Douglas County

PERMIT NO. Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Brown Clay and Cobbles</u>		<u>0</u>	<u>80</u>	<u>80</u>
<u>Loose SAND & GRAV.</u>		<u>80</u>	<u>103</u>	<u>23</u>
<u>Clay with SAND and GRAV. STRATS</u>	<u>→</u>	<u>103</u>	<u>226</u>	<u>123</u>
<u>SAND & GRAV</u>	<u>—</u>	<u>226</u>	<u>260</u>	<u>34</u>

8. WELL CONSTRUCTION

Depth Drilled _____ Feet Depth Cased _____ Feet

HOLE DIAMETER (BIT SIZE)

From _____ To _____
10 1/2 Inches 0 Feet 260 Feet

Inches _____ Feet _____ Feet
 Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/8</u>	<u>11</u>	<u>.188</u>	<u>+1</u>	<u>260</u>

Perforations:

Type perforation Factory Milled
 Size perforation 3/32

From 220 feet to 260 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout

Depth of Seal 55

Placement Method: Pumped Poured

Gravel Packed: Yes No
 From 55 feet to 260 feet

9. WATER LEVEL

Static water level 103 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature Cold °F Quality Clear

Date started 7-11, 1994
 Date completed 7-15, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>20</u>	<u>77A</u>	<u>2</u>

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Enloe Drilling Co. Contractor
 Address P.O. Box 1345 Dayton Nev Contractor

Nevada contractor's license number issued by the State Contractor's Board 4739A

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1480

Signed Lee A. Enloe
 By driller performing actual drilling on site or contractor

Date 7-18-94

