

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25277

1. OWNER DOUGLAS COUNTY ADDRESS AT WELL LOCATION DOUGLAS COUNTY LANDFILL
 MAILING ADDRESS POST OFFICE BOX 218 PINENUT ROAD GARDNERVILLE NEVADA
MINDEN NEVADA 89423

2. LOCATION NW 1/4 SW 1/4 Sec. 18 T. 12 N/S R. 21 E DOUGLAS County
 PERMIT NO. W-193 B Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL AND LARGE COBBLES		0	18	18
SANDY GRAVEL AND CLAY		18	43	25
CLAY AND COURSE GRAVEL		43	47	4
COURSE GRAVEL WITH CLAY LAYERS		47	139	98
SANDY CLAY WITH TRACE GRAVEL		139	176	37
SAND, CLAY AND GRAVEL		176	292	116
COURSE SANDY GRAVEL WITH TRACE OF CLAY		292	325	33
COURSE TO SANDY GRAVEL WITH TRACES OF CLAY (HARD)		325	340	15

8. WELL CONSTRUCTION
 Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)
 From 9 7/8 Inches To 0 Feet 360 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5	10.79	.188	+ 3	300

Perforations:
 Type perforation wire wrap screen
 Size perforation .020
 From 300 feet to 360 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 281 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 281 feet to 360 feet

9. WATER LEVEL
 Static water level 262.45 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name SARGENT IRRIGATION COMPANY Contractor
 Address 9955 NORTH VIRGINIA STREET Contractor
RENO NEVADA 89506
 Nevada contractor's license number issued by the State Contractor's Board 0021246
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1493
 Signed Thomas H. Holm
 By driller performing actual drilling on site or contractor
 Date JUNE 30, 1994

Date started JUL 15 1994
 Date completed MAY 28 1994

7. WELL TEST DATA

TEST METHOD: Pump Bailer Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
3.37	3.2	4.5