

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13108

1. OWNER NEVADA POWER CO / REID GARDNER STA ADDRESS AT WELL LOCATION REID GARDNER FACILITY
 MAILING ADDRESS P.O. BOX 77
MOAPA NV 89025
 2. LOCATION NW 1/4 SE 1/4 Sec 5 T 15 NR 66 E CLARK County
 PERMIT NO. MO-2455 Issued by Water Resources Parcel No. 690-250-013 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE SW-1
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
FILL		0	1.5	1.5
SANDY CLAY		1.5	7	5.5
SANDY GRAVEL		7	8	1
INTERBEDDED SANDS + CLAYS		8	19	11
SANDY SILT		19	20	1
SILTY SAND		20	21	1
SILTY CLAY - PART. CUT.		21	25	4
SANDS + CLAYS		25	29	4
CEMENTED SAND/GRAVEL		29	29.5	0.5
SAND		29.5	34	4.5

8. WELL CONSTRUCTION
 Depth Drilled 34 Feet Depth Cased 34 Feet
 HOLE DIAMETER (BIT SIZE)
 From 8 Inches To 0 Feet 34 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2.375</u>	<u>0.64</u>	<u>0.154</u>	<u>0</u>	<u>34</u>

Perforations:
 Type perforation FACTORY SLOT
 Size perforation 0.010
 From 31.5 feet to 34 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0-25/25-29 BENTONITE Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 29 feet to 34 feet

RECEIVED
 JUL 15 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

Date started JUNE 9 1994
 Date completed JUNE 9 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMAS HIGHT
 Address 4670 SO. POLARIS AVE
LAS VEGAS NV 89103
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on site driller M1869
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date JULY 12, 1994