

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in  
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25960

1. OWNER Randy Wishart ADDRESS AT WELL LOCATION 4770 Raindance  
 MAILING ADDRESS Stage Coach, NV 89429  
 2. LOCATION NW 1/4, SW 1/4 Sec. 35 T. 15 N/S R. 23 E. 21 N County \_\_\_\_\_  
 PERMIT NO. N/A Issued by Water Resources Parcel No. 15-081-23 Subdivision Name Stage Coach

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other Mod

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Soil boulders</u>		<u>1</u>	<u>2</u>	<u>2</u>
<u>Boulders gravel</u>		<u>2</u>	<u>30</u>	<u>28</u>
<u>Cemented gravel</u> <u>(Some boulders)</u>		<u>30</u>	<u>110</u>	<u>80</u>
<u>Clay</u>		<u>110</u>	<u>158</u>	<u>48</u>
<u>Clay, Gravel</u>		<u>158</u>	<u>230</u>	<u>72</u>
<u>Sand, Gravel</u>	<input checked="" type="checkbox"/>	<u>230</u>	<u>245</u>	<u>15</u>
<u>Gravel</u>	<input checked="" type="checkbox"/>	<u>245</u>	<u>259</u>	<u>14</u>

8. WELL CONSTRUCTION  
 Depth Drilled 259 Feet Depth Cased 260 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 5/8 Inches To 259 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>1.88</u>	<u>+1</u>	<u>259</u>

Perforations:  
 Type perforation 3 Tooth Pear  
 Size perforation 3/16 x 3/8 x 4 no. on pear  
 From 229 feet to 259 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Depth of Seal 60  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 60 feet to 259 feet

9. WATER LEVEL  
 Static water level 170 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature 62 °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name James D. Williams, Inc. Contractor  
 Address PO. 555 Contractor  
25 NV 89429  
 Nevada contractor's license number issued by the State Contractor's Board 0031841  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1876  
 Signed James D. Williams  
 By driller performing actual drilling on site or contractor  
 Date 7/1/94

Date started 6/22/94, 19\_\_\_\_  
 Date completed 6/23/94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>18-20</u>		<u>4 3/4 hrs</u>