WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45738
Permit No.
Basin 179

NOTICE OF INTENT NO. 24640

1. OWNER Phil Henry
MAILING ADDRESS 1843 Somersby Way
Green Valley, NV 89014

ADDRESS AT WELL LOCATION ½ mile No. of Ely

2. LOCATION SW ¼ SE ¼ Sec. 9 T. 16 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) Parcel No. Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand and Gravel		5	30	25
Coarse Gravel		30	50	20
Sand and Coarse Gravel		50	120	70
Sand and Small Gravel		120	180	60
Clay and Coarse Gravel		180	200	20
Brown Clay	x	200	210	10
Brown Clay/Small Gravel		210	250	40
Coarse Gravel/Brown Clay	x	250	260	10
Brown Clay/Gravel		260	310	50
Sand and Gravel	x	310	320	10
Clay and Small Gravel		320	360	40

'94 AUG -4 P1:07
STATE ENGINEER

Date started 2/7, 19 94
Date completed 3/3, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
30	152	4

8. WELL CONSTRUCTION
Depth Drilled 360 Feet Depth Cased 360 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches	0 Feet	360 Feet	
Inches	Feet	Feet	
Inches	Feet	Feet	

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	360

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 6 rows
From 240 feet to 260 feet
From 280 feet to 360 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 360 feet

9. WATER LEVEL
Static water level 208 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
Signed (By driller performing actual drilling on site or contractor)
Date 8/01/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627