

PRINT OR TYPE ONLY  
DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
Please complete this form in its entirety in  
accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27599

1. OWNER Jim Hutzler ADDRESS AT WELL LOCATION \_\_\_\_\_  
MAILING ADDRESS 23 UPPER COLONY \_\_\_\_\_  
WELLINGTON, NV 89444 \_\_\_\_\_  
2. LOCATION W 1/2 1/4 SE 1/4 Sec. 34 T 11 R 23 E LYON County  
PERMIT NO. 10-361-26 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
TOPSOIL/SMALL ROCKS		0	15	
GRUS w/ SM. ROCKS		15	45	
BA CRAY w/ SOME GRUS		45	110	
GRUS w/ WT BRN CRAY	WB	110	255	
HEAVY BRN CRAY		255	260	

8. WELL CONSTRUCTION  
Depth Drilled 260 Feet Depth Cased 260 Feet  
HOLE DIAMETER (BIT SIZE)  
From 12 7/8 Inches To 0 Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 3/4</u>		<u>1 9/8</u>	<u>0</u>	<u>260</u>

Perforations:  
Type perforation FACTORY TORCH CUT  
Size perforation 3 x 3/32  
From 200 feet to 220 feet FACTORY  
From 220 feet to 260 feet TC  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
Surface Seal:  Yes  No Seal Type:  
Depth of Seal 100  Neat Cement  
Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
Gravel Packed:  Yes  No  
From 100 feet to 260 feet

9. WATER LEVEL  
Static water level 120 feet below land surface  
Artesian flow --- G.P.M. \_\_\_\_\_ P.S.I.  
Water temperature COLD °F Quality G-0010

Date started 8 21 94  
Date completed 9 10 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>4.5</u>	<u>UT</u>	<u>6 1/2</u>

10. DRILLER'S CERTIFICATION  
This well was drilled under my supervision and the report is true to the best of my knowledge:  
Name ED MILLER Contractor  
Address P.O. BOX 92 Contractor  
SMITH, NV 89430 Contractor  
Nevada contractor's license number 32166  
issued by the State Contractor's Board  
Nevada driller's license number issued by the 1949  
Division of Water Resources, the on-site driller.  
Signed [Signature]  
By driller performing actual drilling on site or contractor  
Date 9 20 94