

OFFICE USE ONLY
Log No. 45780
Permit No. _____
Basin 102

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24699

1. OWNER Guard L.T.D. ADDRESS AT WELL LOCATION 1465 West 10th
MAILING ADDRESS 3130 Villa Marbella Cir Silver Springs
Reno, NV 89509-6602

2. LOCATION SW 1/4 NE 1/4 Sec 24 T 17 N R 24 E Lyon County
PERMIT NO. 17-415-08 Parcel No. _____ Subdivision Name Pawnee Sub#1

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>course sand and</u> <u>gobble stones</u> <u>balter sand some</u> <u>brown clay</u>		<u>0</u>	<u>87</u>	<u>87</u>
<u>course sand and</u> <u>cobble stones</u>	<u>X</u>	<u>87</u>	<u>137</u>	<u>50</u>
<u>gray clay</u>		<u>137</u>	<u>140</u>	<u>3</u>

JUL 26 AM 58
STATE ENGINEERS OFF

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)
From 0 Feet 140 Feet
Inches _____ Feet _____ Feet
Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>		<u>.188</u>	<u>+1</u>	<u>140</u>

Perforations:
Type perforation Mill
Size perforation 18x3
From 120 feet to 140 feet
From _____ feet to _____ feet
From _____ feet to _____ feet
From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
Depth of Seal 50 Neat Cement
Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 87 feet below land surface
Artesian flow _____ G.P.M. _____ P.S.I.
Water temperature cold °F Quality good

Date started 7/15 1994
Date completed 7/18 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>18</u>	<u>2</u>	<u>2</u>

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name ACE Drilling + Dev. Contractor
Address P.O. Box 668 Contractor
Silver Springs, NV 89429
Nevada contractor's license number 14299
issued by the State Contractor's Board
Nevada driller's license number issued by the 726
Division of Water Resources, the on-site driller

Signed H.L. [Signature]
By driller performing actual drilling on site or contractor
Date 7/19/94