

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

**WELL DRILLER'S REPORT**  
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12592

1. OWNER HLA ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 4170 S. BURNING AVE MOHA S. STANLEY  
LV NV 89103  
 2. LOCATION NW 1/4 NW 1/4 Sec 34 T 20 N 96 E CTR County \_\_\_\_\_  
 PERMIT NO. MB 2361 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other TRUCK

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>clay</u>		<u>0</u>	<u>15</u>	
<u>clay with</u>		<u>15</u>	<u>18</u>	
<u>clay with</u>				
<u>small rocks</u>		<u>18</u>	<u>26</u>	
<u>clay with</u>				
<u>small</u>		<u>26</u>	<u>35</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 35 Feet Depth Cased 35 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 35 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4.5</u>	<u>POL</u>	<u>2.440</u>	<u>0</u>	<u>5</u>

Perforations:  
 Type perforation SLOT HED SCREEN  
 Size perforation 1/2"  
 From 5 feet to 35 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 3  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 7 feet to 35 feet

RECEIVED  
 SEP 15 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 5-13 1994  
 Date completed 5-13 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

9. WATER LEVEL  
 Static water level 26 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WIZEN ENVIRONMENTAL Contractor  
 Address 4321 S. VARELY DR #21 Contractor  
LV NV 89103  
 Nevada contractor's license number issued by the State Contractor's Board CO 35137  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller M-910  
 Signed \_\_\_\_\_  
 By driller performing actual drilling on site or contractor  
 Date 9-1-94