

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
 WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 45795
 Permit No. _____
 Basin 162
 NOTICE OF INTENT 10/23/22

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Ed Beeman ADDRESS AT WELL LOCATION 120 Blosser RD PUNU
 MAILING ADDRESS None

2. LOCATION SW 1/4 SW 1/4 Sec 34 T. 19 N/S R. 53 E NYT County _____
 PERMIT NO. _____ Parcel No. 29-601-07 Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Sand</u>		<u>0</u>	<u>10</u>	<u>10</u>
<u>Clay</u>		<u>10</u>	<u>120</u>	<u>110</u>
	<u>100</u>			

8. WELL CONSTRUCTION
 Depth Drilled 120 Feet Depth Cased 120 Feet

HOLE DIAMETER (BIT SIZE)
 From 15 3/4 Inches To 0 Feet 130 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>4 5/16</u>		<u>203</u>	<u>0</u>	<u>120</u>

Perforations:
 Type perforation Total
 Size perforation 1/4" x 6"
 From 100 feet to 120 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 100 feet

RECEIVED
 OCT 03 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

9. WATER LEVEL
 Static water level 60 feet below land surface
 Artesian flow None G.P.M. _____ P.S.I. _____
 Water temperature 67 °F Quality good

Date started 8-14 1994
 Date completed 8-29 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>80</u>	<u>10'</u>	<u>2.0</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Bruce Robinson Contractor
 Address PO 8307 PUNU 89041 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 15972
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 944
 Signed Bruce Robinson By driller performing actual drilling on site or contractor
 Date 8-29-94