

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12835

1. OWNER KELLY FELON ADDRESS AT WELL LOCATION 131 N. LV BLVD  
 MAILING ADDRESS 6850 S. PARADISE  
LV NO 89119

2. LOCATION NW 1/4 NE 1/4 Sec. 34 T. 20 N. R. 61 E. CLARK County \_\_\_\_\_  
 PERMIT NO. MD 2454 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other 76in

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>CLAY</u>		<u>0</u>	<u>7</u>	
<u>CLAY</u>		<u>7</u>	<u>12</u>	
<u>CLAY WITH SOME SANDS &amp; FINES</u>		<u>12</u>	<u>30</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 30 Feet Depth Cased 30 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 30 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>45</u>	<u>PVC</u>	<u>SCH 40</u>	<u>0</u>	<u>10</u>

Perforations:  
 Type perforation SLOT HOLE SCREEN  
 Size perforation 1.020  
 From 10 feet to 30 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal \_\_\_\_\_  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 9 feet to 30 feet

RECEIVED  
 SEP 15 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Date started 6-22, 1994  
 Date completed 6-22, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL  
 Static water level 18 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Wesley Environmental Contractor  
 Address 4321 S. Valley View #21 Contractor  
LV NO 89103  
 Nevada contractor's license number issued by the State Contractor's Board 0035639  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller W1910  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9-6-94