WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45832
Permit No.
Basin 091

NOTICE OF INTENT NO. 20723

1. OWNER ROBERT JORDAN
MAILING ADDRESS P.O. Box 668
Verdi, Nevada 89439

ADDRESS AT WELL LOCATION
825 Hill Lane
Verdi, Nevada

2. LOCATION NW ¼ NW ¼ Sec 18 T 19N N/S R 18 E Washoe County

PERMIT NO. (Issued by Water Resources) 038-08-13 (Parcel No.) Verdi area (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Boulder, gravels and sand with brown clay		0	12	12
Decomposed granite		12	19	7
Granite boulder		19	23	4
Boulders, gravels and sands with brown clay		23	40	17
Brown clay		40	49	9
Smaller boulders and gravels, some brown clay		49	98	49
Gray clay		98	128	30
Dark brown clay		128	170	42
Gray clay		170	180	10
Soft zone	X	180	185	5
Gray clay		185	190	5
Dark brown clay		190	212	22
Soft zone	X	212	216	4
Dark brown clay		216	222	6
Gray clay		222	230	8
soft zone	X	230	235	5
Gray clay		235	250	15

Date started 7-5-94, 19
Date completed 7-6-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25		

8. WELL CONSTRUCTION
Depth Drilled 250 Feet Depth Cased 250 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	100 Feet
8 5/8 Inches		100 Feet	250 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	250

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 180 feet to 200 feet
From 220 feet to 240 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 100 feet
Placement Method: ☒ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 100 feet to 250 feet

9. WATER LEVEL
Static water level 90 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370
RENO, NEVADA 89510 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 8, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627