

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25638

1. OWNER MONTE GILLESPIE ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 120 2nd Street 4600 N Virginia Street
Reno, NV 89501 Reno, NV 89501
 2. LOCATION SW 1/4 NW 1/4 Sec. 26 T. 20 S R. 19 E Washoe County
 PERMIT NO. M/O 717 C&B Parcel No. N/A Subdivision Name _____
Issued by Water Resources

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GM MW -7				
Asphalt		0	3"	3"
Brown clay with tan green rock		3"	70'	69 3/4"
Tan green some white rock with fractured zone	85	70	106'	40'
Tremie #8 -12 silica sand to -30				
Placed 3/8 chip bentonite seal from -28 to -30				
Neat cement -1 to -28'				
Well monument set flush with asphalt and cemented in with concrete grout				

8. WELL CONSTRUCTION
 Depth Drilled 106' Feet Depth Cased 106' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10" Inches To 0' Feet 106' Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	PVC	SCH 40	-3"	-106

Perforations:
 Type perforation slots
 Size perforation .020
 From -36 feet to -106 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 28 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From -30 feet to -106 feet

9. WATER LEVEL
 Static water level 56 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name HACKWORTH DRILLING, INC. Contractor
 Address P.O. Box 850 Contractor
ELKO, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed [Signature] Driller performing actual drilling on site or contractor
 Date June 27 1994

Date started June 6, 1994
 Date completed June 6, 1994

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
	<u>N/A</u>		