

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 25638

1. OWNER Monte Gillespie ADDRESS AT WELL LOCATION 4600 N. Virginia Street
 MAILING ADDRESS 120 2nd Street Reno, NV 89501
 2. LOCATION SW 1/4 NW 1/4 Sec. 26 T. 20 N/S R. 19 E Washoe County
 PERMIT NO. M/O 717 C&B N/A N/A
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
GM MW -8				
Asphalt		0	3"	3"
Brown green rock with streaks of brown clay		3"	90'	89 3/4'
Brown green tan fractured rock		90	95	5'
Grey clay		95	107	12'
Tremie #8-12 silica sand from -107' to -28'				
3/8 chip bentonite seal placed from -28 to -25'				
Well monument cemented in flush with asphalt with concrete grout				

8. WELL CONSTRUCTION
 Depth Drilled 107' Feet Depth Cased 107' Feet
 HOLE DIAMETER (BIT SIZE)
 From 10 Inches To 0 Feet 107 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4"	pvc	Sch 40	-3"	107

Perforations:
 Type perforation slots
 Size perforation .020
 From -37' feet to -107' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 25 _____
 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From -28 feet to -107 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow N/A G.P.M. _____ P.S.I. _____
 Water temperature _____ °F Quality _____

Date started June 7, 19 94
 Date completed June 7, 19 94

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			
		<u>N/A</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Hackworth Drilling, Inc. Contractor
 Address P.O. Box 850 Contractor
Elko, NV 89803
 Nevada contractor's license number issued by the State Contractor's Board 020582
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1654
 Signed John C. Dein
 By driller performing actual drilling on site or contractor
 Date June 27 1994