14 Book

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
Well Designation BLM W 2
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK
Bureau of Land Management

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45857
Permit No.
Basin 212

NOTICE OF INTENT NO. 9424

1. OWNER CC Johnson Malhotra
MAILING ADDRESS 12567 W Cedar Dr Suite 220 Lakewood Colorado 80228
ADDRESS AT WELL LOCATION Henderson Nevada Landfill Site

2. LOCATION ¼ SE ¼ Sec. 29 T. 21 N/S R. 63 E Clark County
PERMIT NO. M02474 Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Odex

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Med Sand w/ Gravel		0	15	15
Gravel Sand 3-6" Cobble	30	15	40	25
Fine layers of tan Clay		40	42½	

RECEIVED
SEP 19 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

'94 SEP 15 P 3:52
STATE ENGINEER'S OFFICE

Date started 8-1-94, 19
Date completed 8-1-94, 19

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	5	½

8. WELL CONSTRUCTION
Depth Drilled 42½ Feet Depth Cased 32½ Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
7 3/8	0	42½

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	RVC	.187	0	32½

Perforations:
Type perforation Machine Slotted
Size perforation .010
From 32½ feet to 42½ feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 30
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 30 feet to 42½ feet

9. WATER LEVEL
Static water level 31 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boyles Bros Drilling Co (Contractor)
Address 1707 S. 1490 W Salt Lake City Ut (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1883
Signed Larry E Hall (By driller performing actual drilling on site or contractor)
Date 8-18-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627