

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 21867

1. OWNER SPRING CREEK BUILDERS ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 2255 Glendale Ave. #4 10975 Silver Knolls Blvd.  
Sparks, Nevada 89431 Reno, Nevada 89506  
 2. LOCATION SW 1/4 SW 1/4 Sec. 24 T. 21N N/S R. 18 E Washoe County  
 PERMIT NO. 086-203-25 Silver Knolls  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Fill, sand & well rock		180	183	3
Medium to coarse sands	X	183	196	13
Sandy brown clay		196	212	16
Soft zone		212	214	2
Sandy brown clay		214	239	25
Soft zone	X	239	247	8
Sandy brown clay		247	255	8
Soft sandy brown clay		255	260	5
Soft zone	X	260	270	10
Soft sandy brown clay		270	275	5

8. WELL CONSTRUCTION  
 Depth Drilled 92 Feet Depth Cased 275 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches 180 Feet 275 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5" OD		.188	0	275

Perforations:  
 Type perforation factory sawd slot  
 Size perforation 3/32 x 3 x 5 around  
 From 190 feet to 210 feet  
 From 230 feet to 270 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No deepening Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout  
 Placement Method:  Pumped  Poured  
 Gravel Packed:  Yes  No  
 From 180 feet to 275 feet

9. WATER LEVEL  
 Static water level 160 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 16 P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number issued by the State Contractor's Board 22549  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923  
 Signed [Signature] By driller performing actual drilling on site or contractor  
 Date July 11, 1994

Date started 7-7-94 19\_\_\_\_  
 Date completed 7-7-94 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>16</u>		