In Book

WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY
PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

Well Designation BLM#1

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45866
Permit No.
Basin 212

NOTICE OF INTENT NO. 9424

Bureau of Land Management

1. OWNER CC Johnson Malhotra
MAILING ADDRESS 12567 W. Cedar Dr Suite 220
Lakewood Colorado 80228

ADDRESS AT WELL LOCATION Henderson Nevada Landfill Site

2. LOCATION ¼ SE ¼ Sec. 29 T 21 N/S R 63 E Clark County

PERMIT NO. MD 2474 (Issued by Water Resources) | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☑ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sand & Coarse Gravel		0	15	15
Intermit Brown Clay w Gravel		15	32	17
Coarse Sand & Gravel	30	32	42	10

RECEIVED
SEP 19 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

'94 SEP 15 P 3:52
RECEIVED
STATE ENGINEERS OFFICE

Date started 8-15, 1994
Date completed 8-16, 1994

7. WELL TEST DATA
TEST METHOD: ☑ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
5	5	1/2

8. WELL CONSTRUCTION
Depth Drilled 42 Feet Depth Cased 22 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From	To
7 3/8	0	42

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	PVC	.187	0	22

Perforations:
Type perforation Machine Slotted
Size perforation .010
From 22 feet to 42 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 22
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☑ Cement Grout ☐ Concrete Grout
Gravel Packed: ☑ Yes ☐ No
From 20 feet to 42 feet

9. WATER LEVEL
Static water level 33 feet below land surface
Artesian flow NO G.P.M. / P.S.I.
Water temperature N/A °F Quality N/A

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Boyles Bros Drilling Co (Contractor)
Address 1907 S. 4490 W. Salt Lake City Ut (Contractor)
Nevada contractor's license number issued by the State Contractor's Board 5380
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1883
Signed [signature] (By driller performing actual drilling on site or contractor)
Date 8-16-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627