

OFFICE USE ONLY  
 Log No. 45872  
 Permit No. \_\_\_\_\_  
 Basin 1  
 NOTICE OF INTENT NO. 25465

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER JIM HUTZER ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 23 UPPER COLONY WELLINGTON, NV 89444 \_\_\_\_\_  
 2. LOCATION 1/2 1/4 SE 1/4 Sec 34 T 11 N/S R 23 LYON County  
 PERMIT NO. 10-361-21 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOPSOIL & SM ROCKS		0	25	
HEAVY GRAVEL		25	50	
BRN CLAY w/ GRAVELS		50	95	
SM GRAVELS w/ SOME BRN CLAY w/B		95	200	
GRAVELS	WB.	200	235	
HEAVY BRN CLAY		235	240	

8. WELL CONSTRUCTION  
 Depth Drilled 240 Feet Depth Cased 240 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 9 7/8 Inches To 0 Feet 240 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 CASING SCHEDULE  

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 3/8</u>		<u>1 8/8</u>	<u>0</u>	<u>240</u>

 Perforations:  
 Type perforation FACTORY TORCH CUT  
 Size perforation 3X 3/32  
 From 200 feet to 220 feet FACTORY  
 From 220 feet to 240 feet T.C.  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No  
 From 50 feet to 240 feet

'94 SEP 21 10:51  
 STATE ENGINEERS ASSOCIATION

Date started 9 14, 1994  
 Date completed 9 17, 1994

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>30+</u>	<u>0.1</u>	<u>4 1/2</u>

9. WATER LEVEL  
 Static water level 150 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature COLD Quality GOOD

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name ED MILLER Contractor  
 Address P.O. BOX 92 SMLTH, NV 89430 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 32166  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1949  
 Signed [Signature]  
 By driller performing actual drilling on site or contractor  
 Date 9 20 94