WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45873
Permit No.
Basin 107

32 BBDD 1

NOTICE OF INTENT NO. 26934

1. OWNER CEAS Corp
MAILING ADDRESS P.O. Box 61
Smith, NV 89430

ADDRESS AT WELL LOCATION
Albright Road Smith

2. LOCATION NW ¼ NW ¼ Sec. 32 T. 11 N/S R. 24 E. Lyon County
PERMIT NO. 19983 (Issued by Water Resources) | Parcel No. NA | Subdivision Name NA

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☐ Deepen ☒ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☒ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
As per conversation with Division of Water Resources the bottom 80' of this well had caved in.				
2" tremie pipe lowered to 400' level. Pumped 9 bag sand mix with 3% bentonite until flooded to surface of casing				

Date started June 29, 1994
Date completed June 29, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled ____ Feet Depth Cased ____ Feet

HOLE DIAMETER (BIT SIZE)

	From	To
Inches	Feet	Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
16.5"				

Perforations:
Type perforation PERFED FROM 120 TO ~~SURFACE~~ 50'
Size perforation W/ AIR PERFORATOR - SEE ORIGINAL LOG
From #7906 feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet
From ____ feet to ____ feet

Surface Seal: ☐ Yes ☐ No
Depth of Seal
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout
Gravel Packed: ☐ Yes ☐ No
From ____ feet to ____ feet

9. WATER LEVEL
Static water level 110 feet below land surface
Artesian flow ____ G.P.M. ____ P.S.I.
Water temperature ____ °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Humboldt Drilling & Pump Co., Inc. (Contractor)
Address P.O. Box 590 (Contractor)
Winnemucca, NV 89446
Nevada contractor's license number issued by the State Contractor's Board 015234
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1195
Signed C. E. Epple (By driller performing actual drilling on site or contractor)
Date 7-19-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627