WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45875
Permit No.
Basin 090

NOTICE OF INTENT NO. 19256

1. OWNER Del Webb Corp.
MAILING ADDRESS 2231 E. Camelback Rd.
Suite 400, Phoenix, Arizona 85038

ADDRESS AT WELL LOCATION Lake Tahoe
Horizon casino/resort, Stateline, Nev.

2. LOCATION SW ¼ NE ¼ Sec. 27 T 13 N/S R 18 E Douglas County

PERMIT NO. M-0-429 MW 40 Issued by Water Resources | 07-140-08 Parcel No. | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt Overlay		0	1	1
Silty,sandy		1	3	2
Brown sandy clay		3	9	6
Yellow-brown sandy clay		9	23	14
Fine-med. sand,clay	X	23	37	14
Med.-course sand,gravel		37	45	8

Date started July 3, 19 91
Date completed July 3, 19 91

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1	4	3

8. WELL CONSTRUCTION
Depth Drilled 45 ~~12 inches~~ Depth Cased 45 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12	0	45

CASING SCHEDULE Schd. 40

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	45	40
4		Sch 40	20	0

Perforations:
Type perforation Slot
Size perforation .020
From 40 feet to 30 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 6 feet
Placement Method: [X] Pumped [ ] Poured

Seal Type:
[X] Neat Cement
[ ] Cement Grout
[ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 45 feet to 6 feet

9. WATER LEVEL
Static water level 33.5 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Development Corporation (Contractor)
Address 1202 Kentucky Ave. (Contractor)
Woodland, CA 95695
Nevada contractor's license number issued by the State Contractor's Board 012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1638
Signed J. Miller Smith (By driller performing actual drilling on site or contractor)
Date 8-2-91

'94 SEP 15 P3:38 STATE ENGINEER'S OFFICE

1991 AUG 6 AM 11:10 STATE ENGINEER'S OFFICE

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627