WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45878
Permit No.
Basin 090

NOTICE OF INTENT NO. 19256

1. OWNER Del Webb Corp.
MAILING ADDRESS 2231 E. Camelback Road SUite 400, Phoenix, Arizona 85038
ADDRESS AT WELL LOCATION Lake Tahoe Horizon casino/resort, Stateline, NV.

2. LOCATION SW ¼ NE ¼ Sec. 27 T. 13 N/S R. 18 E. Douglas County
PERMIT NO. M-0-429 M.W.44 Issued by Water Resources
07-140-08 Parcel No.
Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[ ] Domestic [ ] Irrigation [X] Test
[ ] Municipal/Industrial [X] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [ ] Rotary [ ] RVC
[ ] Air [X] Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Asphalt overlay		0	.5	.5
Silty clay w/ gravel		.5	8	7.5
Bin clay w/ sand mica flakes	x	8	16	8
Reddish bin clayey sand		16	18	2
Fine to course sand		18	25	7
Course sand, small gravel		25	35	10
Fine sand		35	40	5

'94 SEP 15 P3:38
STATE ENGINEER'S OFFICE

Date started July 8, 1991
Date completed July 9, 1991

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
1.2	0	2.5 hrs.

8. WELL CONSTRUCTION
Depth Drilled 40 Depth Cased 40 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
12 Inches	0 Feet	40 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4		Sch 40	40	0

Perforations:
Type perforation slot
Size perforation .010
From 39.9 feet to 14.5 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 13.5 feet
Placement Method: [X] Pumped [ ] Poured
Seal Type: [X] Neat Cement [ ] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 40 feet to 13.5 feet

9. WATER LEVEL
Static water level 12.4 feet below land surface
Artesian flow n/a G.P.M. n/a P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Water Development Corporation (Contractor)
Address 1202 Kentucky Ave. (Contractor)
Woodland, CA 95695
Nevada contractor's license number issued by the State Contractor's Board 012852
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1638
Signed J. Millal Smith (By driller performing actual drilling on site or contractor)
Date 8-2-91

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627