

OFFICE-USE ONLY
 Log.No. 43880
 Permit No. 103
 Basin. 103

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26571

1. OWNER RON SANDERS ADDRESS AT WELL LOCATION 1020 MARSHA
 MAILING ADDRESS GARDNERVILLE, NV GARDNERVILLE, NV
 2. LOCATION SW 1/4 SW 1/4 Sec. 12 T. 12 N. R. 19 E. DOUGLAS County
 PERMIT NO. 19-220-04 SHERIDAN MEADOWS Subdivision Name
 Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other MVD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Alum fill in casing		70	110	40
DB 1/2 sandy clay		110	121	11
DB 1/2 silt/clay shales		121	163	42
DB 1/2 sandy clay some gravel		163	176	13
DB 1/2 gravel	KXX	176	200	24

1994 SEP - 8 AND 14
 STATE ENGINEER

8. WELL CONSTRUCTION
 Depth Drilled 200 Feet Depth Cased 200 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
7 7/8 Inches 110 Feet 200 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>17</u>	<u>1.250</u>	<u>0</u>	<u>180</u>
<u>6 5/8</u>	<u>13</u>	<u>1.188</u>	<u>180</u>	<u>200</u>

Perforations:
 Type perforation Factory Slotted
 Size perforation 3 x 3/32
 From 180 feet to 200 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Neat Cement
 Cement Grout
 Concrete Grout
 Depth of Seal _____
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 200 feet

9. WATER LEVEL
 Static water level _____ feet below land surface
 Artesian flow 2 G.P.M. P.S.I.
 Water temperature 60.6 °F Quality good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC Contractor
 Address 7780 CURRY RD Contractor
FALLOON, NV 89406
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1535
 Signed Jacob W. Phinney
 By driller performing actual drilling on site or contractor
 Date 8-19-94

Date started 8-17 1994
 Date completed 8-19 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
<u>Air</u>	<u>25+</u>		<u>3</u>