

OFFICE USE ONLY
 Log No. 45888
 Permit No. _____
 Basin 105

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26560

1. OWNER NEVADA JOHNSON ADDRESS AT WELL LOCATION 1887 ARABIAN GARDNERVILLE
 MAILING ADDRESS GARDNERVILLE, NV

2. LOCATION SE 1/4 NW 1/4 Sec 24 T. 12 N. R. 20 E. DOUGLAS County
 PERMIT NO. 29-480-46 Parcel No. RUMENSTROTH Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other MUD

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	2	2
CEMENTED GRAVEL		2	10	8
SANDY CLAY		10	32	22
CEMENTED GRAVEL		32	49	17
CEMENTED SAND CLAY		49	69	20
CEMENTED SAND		69	91	22
CEMENTED GRAVEL		91	102	11
CEMENTED GRAVEL		102	124	22
SANDY CLAY		124	128	4
CEMENTED GRAVEL	✓	128	160	32

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)
 From 10 5/8 Inches To 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 5/8</u>	<u>13</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation FACTORY SLOTTED
 Size perforation 3 x 3/32
 From 140 feet to 160 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 75 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD °F Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name EDDCO EXPLORATION, INC. Contractor

Address 7780 CURRY RD. FALLON, NV 89406 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 27673
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1726
 Signed Pat J. Moore By driller performing actual drilling on site or contractor
 Date 8-23-94

Date started 8-17 1994
 Date completed 8-23 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>AIR</u>	<u>25+</u>	<u>—</u>	<u>2</u>