

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26481

1. OWNER JOHN JOHNSON ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS 10235 Black Hawk 10795 Santa Fee  
Reno, NV 89506 Reno, NV 89506  
 2. LOCATION NE 1/4 NW 1/4 Sec 25 T 21N N/S R 18 Washoe County  
 PERMIT NO. 086-818-03 Silver Knolls  
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other \_\_\_\_\_

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
WELL DEEPENING:				
Brown granite sands		90	92	2
Brown sandy clay		92	111	19
Med. brown sand, some clay streaks		111	148	37
Brown clay		148	152	4
Med. brown to gray sand, some clay streaks		152	173	21
Brown clay		173	175	2

8. WELL CONSTRUCTION  
 Depth Drilled 175 Feet Depth Cased 175 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 6 1/8 Inches To 92 Feet  
175 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
5"OD		.188	0	175

Perforations:  
 Type perforation factory sawed XXXX slot  
 Size perforation 3/32 x 3 x 5 around  
 From 109 feet to 169 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal deepening  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 90 feet to 175 feet

9. WATER LEVEL  
 Static water level 82 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. 20+ P.S.I.  
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name WAYNE DRILLING, INC. Contractor  
 Address P.O. BOX 12370 Contractor  
RENO, NEVADA 89510  
 Nevada contractor's license number 22549  
 issued by the State Contractor's Board  
 Nevada driller's license number 923  
 issued by the Division of Water Resources, the on-site driller  
 Signed [Signature]  
 by driller performing actual drilling on site or contractor  
 Date July 26, 1994

Date started 7-25-94, 19\_\_\_\_  
 Date completed 7-25-94, 19\_\_\_\_

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>20+</u>			