WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45894
Permit No.
Basin 6123

NOTICE OF INTENT NO. 27289

1. OWNER FRED WILLIAMS
MAILING ADDRESS 11577 Deodar
Reno, Nevada 89506

ADDRESS AT WELL LOCATION Same

2. LOCATION NW ¼ SE ¼ Sec. 15 T 21N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 080-372-12 (Parcel No.) Lemmon Valley (Subdivision Name)

3. WORK PERFORMED
☐ New Well ☐ Replace ☐ Recondition
☒ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| WELLDEEPENING: | | | | |
| Large gravels & sand | | 143 | 152 | 9 |
| Med. to fine sand | X | 152 | 168 | 16 |
| Med. sand | X | 168 | 179 | 11 |
| Med to coarse sand | X | 179 | 200 | 21 |

Date started 8-1-94, 19
Date completed 8-1-94, 19

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)

| | From | To |
|---|---|---|
| 6 1/8 Inches | 143 Feet | 200 Feet |
| Inches | Feet | Feet |
| Inches | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 5" OD | | .188 | 0 | 200 |

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 133 feet to 193 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal deepening
Placement Method: ☐ Pumped ☐ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 140 feet to 200 feet

9. WATER LEVEL
Static water level 85 feet below land surface
Artesian flow G.P.M. 25 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 3, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627