WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45896
Permit No.
Basin 085

NOTICE OF INTENT NO. 27283

1. OWNER MIKE BROWNING
MAILING ADDRESS 5515 Wedekind Road
Sparks, NV 89431

ADDRESS AT WELL LOCATION
Campo Rico
Sparks, NV

2. LOCATION SW ¼ NE ¼ Sec. 26 T. 21N N/S R. 20 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-360-66 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay with DG mix		1	9	8
Brown sandy clay		9	36	27
Decomposed granite		36	38	2
Brown clay		38	49	11
Decomposed granite		49	55	6
Brown sandy clay		55	91	36
Fine granite sands	X	91	96	5
Brown sandy clay		96	120	24
Med. granite sands		120	135	15
Brown sandy clay		135	153	18
Granite sands weathered	X	153	154	1
Soft sandy clay		154	170	16

Date started 7-19-94, 19
Date completed 7-20-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 170 Feet Depth Cased 170 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	170 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	170

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 120 feet to 160 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured

Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 170 feet

9. WATER LEVEL
Static water level 100 feet below land surface
Artesian flow G.P.M. 18 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. BOx 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 25, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627