WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45897
Permit No.
Basin 085

NOTICE OF INTENT NO. 27287

1. OWNER NOEL & MALISSA COBB
MAILING ADDRESS 1211 Charles Dr.
Reno, NV 89509

ADDRESS AT WELL LOCATION
175 Quivira
Sparks, NV

2. LOCATION SW ¼ SW ¼ Sec. 9 T. 21 N N/S R. 21 E. Washoe County
PERMIT NO. (Issued by Water Resources) 076-310-29 (Parcel No.) Spanish Springs (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	3	3
Brown clay, some gravels		3	7	4
Brown clay		7	34	27
White clay		34	41	7
Brown clay		41	90	49
Gray clay		90	96	6
Brown sandy clay		96	197	101
Soft zone (NO WATER)		197	202	5
Brown sandy clay		202	311	109
Green to gray clay		311	331	20
Soft zone (app. 1½ GPM)	X	331	334	3
Gray clay		334	391	57
Brown clay		391	431	40
Multi-color volcanic rock (app 2 GPM)	X	431	480	49
Fracture	X	480	481	1
Multi-colored volcanic rock		481	547	66
Fracture rock	X	547	568	21
Mult-colored volcanic rock		568	575	7

Date started 7-26-94, 19
Date completed 7-29-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 575 Feet Depth Cased 575 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From (Feet)	To (Feet)
10	0	50
8 5/8	50	575

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	575

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 367 feet to 387 feet
From 427 feet to 447 feet
From 487 feet to 507 feet
From 547 feet to 567 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 575 feet

9. WATER LEVEL
Static water level 114 feet below land surface
Artesian flow G.P.M. 17 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. BOX 12370 (Contractor)
RENO, NEVADA 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed [signature] (By driller performing actual drilling on site or contractor)
Date August 2, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627