WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45900
Permit No.
Basin 094

NOTICE OF INTENT NO. 22848

1. OWNER GLENN SINGLEY & NANCY ANDERSON
MAILING ADDRESS 8450 Red Baron Blvd.
Reno, NV 89506
ADDRESS AT WELL LOCATION 106 Cobalt
Reno, NV 89506

2. LOCATION NE ¼ SE ¼ Sec. 12 T. 22N N/S R. 18 E. Washoe County
PERMIT NO. (Issued by Water Resources) 079-381-08 (Parcel No.) Red Rock Estates (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Brown clay, some mixed decomposed granite		1	16	15
D.G. with streaks of clay		16	71	55
Brown clay with some D.G.		71	162	91
Weathered granite		162	188	26
Weathered granite with brown clay		188	216	28
Weathered granite		216	222	6
Fracture	X	222	224	2
Weathered granite some clay streaks		224	263	39
Weathered fracture, rusty	X	263	268	5
Weathered granite		268	273	5
Fracture	X	273	274	1
Weathered granite		274	300	26

Date started 7-11-94, 19
Date completed 7-12-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
15		

8. WELL CONSTRUCTION
Depth Drilled 300 Feet Depth Cased 300 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
10 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	300

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 225 feet to 265 feet
From 275 feet to 295 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 300 feet

9. WATER LEVEL
Static water level 183 feet below land surface
Artesian flow G.P.M. 15 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name WAYNE DRILLING, INC. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510
Nevada contractor's license number issued by the State Contractor's Board 22549
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923
Signed (By driller performing actual drilling on site or contractor)
Date July 15, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627