WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45901
Permit No.
Basin 094

NOTICE OF INTENT NO. 27284

1. OWNER KEVIN & MARY DAVIDSON
MAILING ADDRESS 1910 Prince Way
Reno, NV 89503

ADDRESS AT WELL LOCATION
15032 Red Rock Road
Reno, NV 89506

2. LOCATION SE ¼ SW ¼ Sec. 7 T 22N N/S R 19 E Washoe County
PERMIT NO. (Issued by Water Resources) 079-371-20 (Parcel No.) Red Rock Estates #77 parcel 4 of parcel 4 (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[X] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	1	1
Dark brown clay		1	6	5
Sandy brown clay		6	18	12
Sandy green clay		18	39	21
Brown clay		39	101	62
Green clay		101	188	87
Brown clay		188	230	42
Soft zone (app 2 GPM)	X	230	231	1
BRown clay		231	255	24
Soft zone (app 4 GPM)		255	256	1
Brown clay		256	280	24
Gray clay		280	330	50
Brown sandy clay		330	359	29
Soft zone *app 1 GPM)	X	359	360	1
Brown & gray clay		360	375	15

Date started 7-20-94, 19
Date completed 7-22-94, 19

7. WELL TEST DATA
TEST METHOD: [ ] Bailer [ ] Pump [X] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
7		

8. WELL CONSTRUCTION
Depth Drilled 375 Feet Depth Cased 375 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 5/8 Inches		50 Feet	375 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	375

Perforations:
Type perforation factory sawed slot
Size perforation 3/32 x 3 x 5 around
From 235 feet to 255 feet
From 295 feet to 315 feet
From 355 feet to 375 feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [X] Cement Grout [ ] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 375 feet

9. WATER LEVEL
Static water level 180 feet below land surface
Artesian flow G.P.M. 7 P.S.I.
Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Wayne Drilling, Inc. (Contractor)
Address P.O. Box 12370 (Contractor)
Reno, NV 89510

Nevada contractor's license number issued by the State Contractor's Board 22549

Nevada driller's license number issued by the Division of Water Resources, the on-site driller 923

Signed [signature] (By driller performing actual drilling on site or contractor)
Date July 25, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627