

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

4303

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 27286

1. OWNER MILLIE CENTER/BRADY BITZ ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 3995 Bria Crt. 1209 Serpentine Road
Sparks, NV 89436 Reno, NV 89506
 2. LOCATION SE 1/4 NW 1/4 Sec. 14 T. 22N N/S R. 19 E Washoe County
 PERMIT NO. 079-480-5153 Antelope Valley Red Rock Est. #195 Subdivision Name
Issued by Water Resources Parcel No.

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown clay		0	3	3
Green fine sand		3	8	5
Brown sandy clay		8	61	53
Brown clay		61	88	27
Soft zone (NO WATER)		88	96	8
Brown clay		96	107	11
Fine sand (COULDY WATER DID NOT CLEAN UP NO PERFORATIONS)		107	111	4
Brown clay		111	123	13
Brown sand, soft	X	123	151	28
Weathered granite		151	160	9

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 50 Feet
10 Inches 0 Feet 50 Feet
8 5/8 Inches 50 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8		.188	0	160

Perforations: factory sawed slot
 Type perforation _____
 Size perforation 3/32 x 3 x 5 around _____
 From 115 feet to 155 feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

Date started 8-2-94, 19_____
 Date completed 8-3-94, 19_____

7. WELL TEST DATA

TEST METHOD: <input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift			
G.P.M.	Draw Down (Feet Below Static)	Time (Hours)	
<u>16</u>			

9. WATER LEVEL
 Static water level 92 feet below land surface
 Artesian flow _____ G.P.M. 16 P.S.I.
 Water temperature cold °F Quality clear

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name WAYNE DRILLING, INC.
 Contractor
 Address P.O. BOX 12370
 Contractor
RENO, NEVADA 89510
 Nevada contractor's license number 22549
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 923
 Division of Water Resources, the on-site driller
 Signed [Signature]
 By driller performing actual drilling on site or contractor
 Date August 4, 1994