WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK 23bbc

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45903
Permit No.
Basin 093

NOTICE OF INTENT NO. 22902

1. OWNER NICK BENVIN
MAILING ADDRESS 18055 MARANGO ROAD RENO NV 89511
ADDRESS AT WELL LOCATION 15625 ELKHORN LANE RENO, NV 89506

2. LOCATION NW ¼ NW ¼ Sec. 23 T. 22 N/S R. 19 E. WASHOE County
PERMIT NO. 079-470-67 Red Rock Estates #186 par. 3
Issued by Water Resources | Parcel No. | Subdivision Name

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☑ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☑ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
SANDY CLAY		0	22	
LT. BROWN CLAY		22	40	
LT. BROWN SAND		40	55	
LT. BROWN CLAY		55	58	
SAND		58	62	
LT. BROWN CLAY		62	73	
FINE SAND		73	85	
SANDY CLAY		85	95	
DG AND CLAY		95	124	
SANDY CLAY		124	134	
SANDY CLAY + DG		134	141	
FINE SAND		141	148	
CLAY AND DG		148	149	
SAND AND DG	XX	149	165	
CLAY		165	166	
DG AND FINE SAND		166	173	
CLAY AND SAND		173	195	
DG	XX	195	199	
GREEN SANDY CLAY		199	200	

Date started 6-23, 1994
Date completed 6-27, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☑ Air Lift

	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
APPROX	200	180	2

8. WELL CONSTRUCTION
Depth Drilled 200 Feet Depth Cased 200 Feet

HOLE DIAMETER (BIT SIZE)
9 7/8 Inches From 0 Feet To 200 Feet
Inches Feet Feet
Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	13	.188	140	160
6 5/8	13	.188	180	200
6 5/8		.250	-1	140
6 5/8		.250	160	180

Perforations:
Type perforation MILL SLOT
Size perforation 1/8 X 3
From 140 feet to 160 feet
From 180 feet to 200 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 50+
Placement Method: ☑ Pumped ☐ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No
From 50 feet to 200 feet

9. WATER LEVEL
Static water level 50 feet below land surface
Artesian flow NONE G.P.M. NONE P.S.I.
Water temperature COOL °F Quality GOOD

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name EMDLCO DRILLING (Contractor)
Address P.O. BOX 8056 (Contractor)
RENO, NV 89507
Nevada contractor's license number issued by the State Contractor's Board 32166-C23
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1418
Signed Bruce Miller
By driller performing actual drilling on site or contractor
Date 6-29-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627