

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 26513

1. OWNER Gaylord Rodeman ADDRESS AT WELL LOCATION Redrock Road
 MAILING ADDRESS 6830 Flower Street Reno, NV 89506
 2. LOCATION SE 1/4 NW 1/4 Sec. 296 T 21 N R. 19 E Washoe County
 PERMIT NO. 079-331-05 Parcel No. Red Rock Ex. # 3 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	2	2
Clay		2	35	33
Granite Boulder		35	40	5
Clay		40	48	8
Granite		48	75	27
Clay & Gravel Mix		75	280	205
Granite		280	302	22
Gravel	X	302	304	2
Fractured Granite	X	304	320	16

8. WELL CONSTRUCTION
 Depth Drilled 320 Feet Depth Cased 320 Feet

HOLE DIAMETER (BIT SIZE)
 From To
1.03/4 Inches 0 Feet 320 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	320

Perforations:
 Type perforation Mill Cut
 Size perforation 1/8
 From 280 feet to 320 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 320 feet

Date started July 1, 1994
 Date completed July 7, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

9. WATER LEVEL
 Static water level 240 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality unknown

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Parsons Drilling, Inc. Contractor
 Address P.O. Box 1265 Contractor
Fallon, NV 89407-1265
 Nevada contractor's license number issued by the State Contractor's Board 29064
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1696
 Signed Gaylord Rodeman
 Driller performing actual drilling on site or contractor
 Date July 17, 1994