WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45909
Permit No. 69375
Basin 162

NOTICE OF INTENT NO. 13523

1. OWNER Patrick Grabowski
MAILING ADDRESS SE
ADDRESS AT WELL LOCATION 5240 S. Pahrump Valley Blvd.

2. LOCATION ~~NE~~ ¼ NE ¼ Sec. 10 T. 21-S N/S R 53 E Nye County
PERMIT NO. 69375 - DSB (Issued by Water Resources) | 44-253-04 (Parcel No.) | Plantation Est. (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
~~☒ Domestic~~ Commercial DSB ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Surface | | 0 | 4 | 4 |
| Brown clay | | 4 | 12 | 8 |
| Green clay | | 12 | 28 | 16 |
| Green clay | | 28 | 46 | 18 |
| Brown clay | X | 46 | 78 | 32 |
| Brown clay/caliche | | 78 | 94 | 16 |
| Brown clay | X | 94 | 117 | 23 |
| Brown clay/caliche | X | 117 | 134 | 17 |
| Limestone | | 134 | 140 | 6 |

RECEIVED
NOV 07 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started Oct. 20, 19 94
Date completed Oct. 20, 19 94

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| 20 | 4 | ¼ |

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

| | | From | To |
|---|---|---|---|
| 12 Inches | | 0 Feet | 140 Feet |
| Inches | | Feet | Feet |
| Inches | | Feet | Feet |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 8 5/8 | 16.94 | .188 | 0 | 140 |

Perforations:
Type perforation Factory Cut
Size perforation 1/8"width 3"long (8 rolls)
From 120 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 54 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name JIM PIKE WELL DRILLING, LLC (Contractor)
Address P.O. Box 56 (Contractor)
Pahrump, NV 89041
Nevada contractor's license number issued by the State Contractor's Board 17563
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1812
Signed William A. Pike (By driller performing actual drilling on site or contractor)
Date Oct. 21, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627