WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT
Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45917
Permit No.
Basin 162

NOTICE OF INTENT NO. 14239

1. OWNER Bill Moore
MAILING ADDRESS
ADDRESS AT WELL LOCATION Lot 185 Palm St.

2. LOCATION NW ¼ SW ¼ Sec. 19 T. 19S N/S R. 53 E. NYE County
PERMIT NO. (Issued by Water Resources) 24-433-03 (Parcel No.) Valley View ACRES (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Clay		0	8	8
Calichie		8	11	3
Clay		11	21	10
Calichie		21	24	3
Clay		24	32	8
Calichie		32	36	4
Clay		36	47	11
Calichie	WB	47	50	3
Clay		50	60	10
Calichie	WB	60	64	4
Clay		64	73	9
Calichie	WB	73	76	3
Clay		76	89	13
Calichie	WB	89	92	3
Clay		92	98	6
Calichie	WB	98	100	2

RECEIVED
NOV 15 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started November 3, 19 94
Date completed 11/4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12 1/4 Inches		0 Feet	100 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.42	.188	0	100

Perforations:
Type perforation Factory Saw cut
Size perforation 1/8x3"
From 80 feet to 100 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☒ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 100 feet

9. WATER LEVEL
Static water level 52 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling (Contractor)
Address HCR 78 Box 8035N (Contractor)
Pahrump, NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1642
Signed Thomas Dan
By driller performing actual drilling on site or contractor
Date 11/4/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627