WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 45962
Permit No.
Basin 163

NOTICE OF INTENT NO. 14243

1. OWNER Timothy & Catherine DONOVAN.
MAILING ADDRESS
ADDRESS AT WELL LOCATION Peonia & Head Sandy Valley.

2. LOCATION SW ¼ NE ¼ Sec. 26 T 045 N/S R 56 E Clark County
PERMIT NO. | Issued by Water Resources | 580-240-133 Parcel No. | Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☒ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Sandy Silt		0	9	9
Calichie		9	12	3
Clay		12	17	5
Calichie		17	19	2
Clay		19	28	9
Calichie		28	30	2
Clay		30	42	12
Calichie		42	46	4
Clay		46	55	9
Calichie		55	57	2
Clay		57	69	12
Calichie		69	78	9
Clay		78	92	14
Calichie		92	96	4
Clay		96	101	5
Calichie		101	105	4
Clay		105	113	8
Calichie		113	119	6
Clay		119	126	7
Calichie		126	140	13

RECEIVED
NOV 15 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 11-4, 1994
Date completed 11-5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 140 Feet Depth Cased 140 Feet

HOLE DIAMETER (BIT SIZE)

Inches	From Feet	To Feet
12¼	0	140

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8⅝	16.57	.188	-1	140

Perforations:
Type perforation SAW
Size perforation 1/8 inch by 3 inch.
From 20 feet to 140 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 140 feet

9. WATER LEVEL
Static water level 86 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Great Basin Drilling Contractor
Address HCR 78 Box 80358 Contractor
Pahrump NV. 89041
Nevada contractor's license number issued by the State Contractor's Board 30880
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1426
Signed [signature] By driller performing actual drilling on site or contractor
Date 11-7-94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627