WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 45974
Permit No.
Basin 163

1 Book

Notice of Intent No 13431

1. OWNER Melvin S Liefel ADDRESS Sandy Valley

2. LOCATION S W ¼ NE ¼ Sec. 25 T. 24 N OR S 54 E. Clark County
PERMIT NO.

3. TYPE OF WORK
New Well ☑ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☑ Irrigation ☐ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☐ Rotary ☑
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Brown Clay		0	85	85
Clay + Gravel	✓	85	120	35

RECEIVED
OCT 26 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 8-21, 1994
Date completed 8-23, 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
	air lifted		2 hr

BAILER TEST
G.P.M. 35-40 Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 9 7/8 inches Total depth 120 feet
Casing record 6 5/8
Weight per foot ..... Thickness .188

Diameter	From	To
6 5/8 inches	+1 feet	120 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type Cement
Depth of seal 50 feet
Gravel packed: Yes ☐ No ☑
Gravel packed from [redacted] feet to [redacted] feet

Perforations:
Type perforation Torch
Size perforation 1/4 x 6
From 80 feet to 120 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 70 Feet below land surface
Flow ..... G.P.M.
Water temperature Cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Mitchell Cut
Address 2255 Sunset Rd
Nevada contractor's license number 27030
Nevada driller's license number 1475
Signed Leon Mitchell
Date 9-1-94

USE ADDITIONAL SHEETS IF NECESSARY

O-627