


Log No. 45978

Permit No. 54627

Basin 13-212-1112



PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13439

1. OWNER M. Rao Yerramesetti - Fred Abraham

ADDRESS AT WELL LOCATION El Capitan

2. LOCATION NE 1/4 NW 1/4 Sec 29 T. 19 N. R. 60 E Clark County

PERMIT NO. 54627 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
<u>Boulders & Silty Clay</u>		<u>0</u>	<u>130</u>	<u>130</u>
<u>Brown Clay</u>		<u>130</u>	<u>180</u>	<u>50</u>
<u>Red Clay w/ Gravel & Boulders</u>		<u>180</u>	<u>243</u>	<u>63</u>
<u>Cemented Gravels</u>		<u>243</u>	<u>290</u>	<u>47</u>
<u>Fractured Sandstone</u>	<u>X</u>	<u>290</u>	<u>400</u>	<u>110</u>

8. WELL CONSTRUCTION
 Depth Drilled 400 Feet Depth Cased 400 Feet

HOLE DIAMETER (BIT SIZE)
12 1/4 Inches From 0 Feet To 400 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>		<u>.188</u>	<u>+1</u>	<u>400</u>

RECEIVED

DEC 02 1994

Div. of Water Resources
Branch Office - Las Vegas, NV

RECEIVED

OCT 20 1994

Div. of Water Resources
Branch Office - Las Vegas, NV

Perforations:
 Type perforation Joch
 Size perforation 14" x 8"
 From 340 feet to 400 feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50ft Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 400 feet

9. WATER LEVEL
 Static water level 230 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cool °F Quality OK

Date started 9/26, 1994
 Date completed 9/29, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>50</u>	<u>Pumped 2 hours</u>	

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Mitchell Enterprises Contractor
 Address 2255 E. Sunset #1056 Contractor
Las Vegas, NV 89119
 Nevada contractor's license number issued by the State Contractor's Board 27030
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1475
 Signed Dean Mitchell
 By driller performing actual drilling on site or contractor
 Date 10-20-94