

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. **10920**

1. OWNER **John JAHANNES** ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS **Box 8073** **BARNEY ST AND GALLY ST**
Pahrump NEV 89041 **Block B Lot #1**
 2. LOCATION **E 1/2 SW 1/4 SE 1/4 Sec 25 T. 19S N/S R. 53 E N45** County _____
 PERMIT NO. **28-243-03** **BELL VISTA UNIT #4**
 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	1	1
HARD BRN CLAY		1	5	4
GREY CALICHE		5	9	4
GREY CLAY		9	24	15
BRN CLAY	WB	24	45	21
HARD BRN CLAY		45	59	14
GREY CLAY	WB	59	91	32
HARD BRN CLAY		91	98	7
BRN CLAY	WB	98	104	6
HARD GREY CLAY		104	140	36

8. WELL CONSTRUCTION
 Depth Drilled **140** Feet Depth Cased **140** Feet
 HOLE DIAMETER (BIT SIZE)
 From To
12 1/2 Inches **0** Feet **140** Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 3/8	17.11	1.88	0	140

Perforations:
 Type perforation **Torch Cut**
 Size perforation **1 1/4" x 6"**
 From **100** feet to **140** feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal **50'**
 Neat Cement
 Placement Method: Pumped Poured
 Concrete Grout
 Gravel Packed: Yes No
 From **140** feet to **50'** feet

RECEIVED
 OCT 18 1994
 Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started **Oct 2** 19**94**
 Date completed **Oct 9** 19**94**

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	1'	1 hr

9. WATER LEVEL
 Static water level **39** feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature **Cold** °F Quality **Good**

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name **Ron Nailon Drilling** Contractor
 Address **Box 265 Pahrump NEV 89041** Contractor
 Nevada contractor's license number issued by the State Contractor's Board **0035704**
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller **1625**
 Signed **Ron Nailon**
 By driller performing actual drilling on site or contractor
 Date **Oct 10 1994**