

STATE OF NEVADA  
 DIVISION OF WATER RESOURCES  
**WELL DRILLER'S REPORT**

OFFICE USE ONLY  
 Log No. 46047  
 Permit No. 52062  
 Basin 212

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.140

NOTICE OF INTENT NO. 12925

1. OWNER James Corbett (Pioneer Well Drilling) ADDRESS AT WELL LOCATION 7350 SOLAR AVE.  
 MAILING ADDRESS 7385 N. Monte Cristo Las Vegas Nev 89131

2. LOCATION SE 1/4 SW 1/4 Sec 15 T. 19S N/S R. 60 E Clark County  
 PERMIT NO. 52062 APN # 125-15-402-014 Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Popcorn Caliche		0	160	
Clay		160	240	
Clay & Water	X	240	245	
Clay		245	340	
Clay		360	535	
Clay & Water	X	535	550	
Hard Limestone		550	600	
Clay & Water	X	600	655	

8. WELL CONSTRUCTION  
 Depth Drilled 655 Feet Depth Cased 655 Feet

HOLE DIAMETER (BIT SIZE)

From	To
12 1/4 Inches	0 Feet 80 Feet
10 5/8" Inches	80 Feet 655 Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	+2	655

Perforations:  
 Type perforation Factory  
 Size perforation 3/16 x 8 row

From 595 feet to 635 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

RECEIVED  
 OCT 11 1994  
 Div. of Water Resources  
 Branch Office - Las Vegas, NV

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 80

Placement Method:  Pumped  
 Poured

Gravel Packed:  Yes  No  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 132 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 7/8/94, 19\_\_\_\_\_  
 Date completed 7/18/94, 19\_\_\_\_\_

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Vernon H. Dimick Contractor  
 Address 5360 Bonita Vista Contractor  
Las Vegas, Nev. 89129

Nevada contractor's license number issued by the State Contractor's Board 10062  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 552

Signed V. H. Dimick  
 By driller performing actual drilling on site or contractor  
 Date 10-10-94