

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. \_\_\_\_\_  
 ADDRESS AT WELL LOCATION Hunter Lake School

1. OWNER USGS  
 MAILING ADDRESS 333 W Nye Ln Carson City NV 89706  
 2. LOCATION SE 1/4 NW 1/4 Sec 15 T 19 N R 19 E Washoe County  
 PERMIT NO. M 0 - 769 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name Hunter Lake School

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
sand silt + clay		0	5	5
clay, sand, + silt		5	7	2
pebbles w/ layered clay sand + silt 2" to 6" thick		7	9.5	1.5
cobbles		9.5	12	3.5
silt, sand, + clay		12	15	3
pebbles + cobbles w/ some sand, silt, + clay		15	30	5
sand, silt, + clay		30	21	1
coarse sand, silt + clay		21	28	7
pebbles + cobbles		28	31	3

8. WELL CONSTRUCTION  
 Depth Drilled 31 Feet Depth Cased 29 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 4.5 Inches To 0 Feet 31 Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 Inches Feet Feet  
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>2</u>	<u>shed 40</u>	<u>PVC</u>	<u>0</u>	<u>29</u>

Perforations:  
 Type perforation factory  
 Size perforation 0.02 inches  
 From 22 feet to 29 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 Surface Seal:  Yes  No Seal Type:  Neat Cement  
 Depth of Seal 5 feet  Cement Grout  
 Placement Method:  Pumped  Concrete Grout  
 Poured  
 Gravel Packed:  Yes  No #16 sand  
 From 9 feet to 31 feet

9. WATER LEVEL  
 Static water level 19.60 6/3/94 feet below land surface  
 Artesian flow NO G.P.M. \_\_\_\_\_ P.S.I. \_\_\_\_\_  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

Date started 5/25, 1994  
 Date completed 5/25, 1994

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift			

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Kathryn C Kilroy Contractor  
 Address 333 W. Nye Ln Carson City NV 89706  
 Nevada contractor's license number issued by the State Contractor's Board \_\_\_\_\_  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller FP-1519  
 Signed Kathryn C Kilroy  
 By driller performing actual drilling on site or contractor  
 Date 5/26/94