WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 46061
Permit No.
Basin 087

PRINT OR TYPE ONLY

NOTICE OF INTENT NO.

1. OWNER USGS
MAILING ADDRESS 333 W Nye Ln Carson City NV 89706
ADDRESS AT WELL LOCATION NE corner Mello Sports complex parking area

2. LOCATION NE ¼ NE ¼ Sec. 10 T. 19 N/S R. 20 E. Washoe County
PERMIT NO. MO-769 (Issued by Water Resources) Parcel No. Mello Sports Complex (Subdivision Name)

3. TYPE OF WORK: New Well ☑ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☐ Irrigation ☐ Test ☑ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☐ Other ☑ auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
dark yellowish brown layered silt & clay		0	3	3
fine sand, silt, & clay		3	8	5
olive grey clay with some silt		8	15	7
silty clay		15	19	4
pea gravel & pebbles		19	20	1
fine sand with some silt & clay		20	23	3
pea gravel, pebbles & cobbles with some silt & clay		23	29	6
pea gravel & pebbles		29	30	1
gravel, sand, silt & clay		30	34	4
pea gravel & pebbles		34	35	1
pea gravel, sand, silt, and clay		35	43	8
sand, silt & clay		43	58	15

Date started 6/23, 1994
Date completed 6/23, 1994

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
N 39.534489 W 119.714867 NAD27		plugged under NOT 6/94	

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 4.5 inches Total depth 58 feet
Casing record PVC sched 40
Weight per foot ..... Thickness .....

Diameter	From	To
2 inches	0 feet	36 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☑ No ☐ Type neat cement
Depth of seal 11 feet
Gravel packed: Yes ☑ No ☐ #16 sand
Gravel packed from 21 feet to 36 feet

Perforations:
Type perforation factory
Size perforation 0.02 inches
From 26 feet to 36 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 26 feet below land surface
Flow NO G.P.M. ..... P.S.I.
Water temperature ..... ° F. Quality .....

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kathryn C Kilroy (Contractor)
Address 333 W Nye Ln (Contractor)
Nevada contractor's license number .....
Nevada contractor's drillers number FP 1519
Nevada driller's license number FP 1519 (Actual Driller)
Signed Kathryn C Kilroy (Contractor)
Date 6/23/94

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434