WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 460062
Permit No.
Basin 687

NOTICE OF INTENT NO.

1. OWNER USGS
MAILING ADDRESS 333 W Nye Ln Carson City NV 89706
ADDRESS AT WELL LOCATION Planter box in SW corner of Getto Bldg parking lot

2. LOCATION NE ¼ SW ¼ Sec. 11 T. 19 N/S R. 20 E Washoe County
PERMIT NO. MO-769 (Issued by Water Resources) Parcel No. Subdivision Name: Getto Transportation Center

3. WORK PERFORMED
☑ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☐ Domestic ☐ Irrigation ☑ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☑ Other auger

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| sand, silt, + clay | | 0 | 0.5 | 0.5 |
| cobbles, pebbles + pea gravel | | 0.5 | 1 | 0.5 |
| greyish brown clay | | 1 | 4 | 3 |
| dark yellowish brown clay with some silt | | 4 | 8 | 4 |
| moderate brown clay w/silt | | 8 | 9 | 1 |
| dark yellowish brown clay w/ some silt | | 9 | 13 | 4 |
| dark greenish grey clay w/silt | | 13 | 19 | 6 |
| pebbles, pea gravel + sand w/ thin clay layers | | 19 | 28 | 9 |
| pea gravel + pebbles | | 28 | 29 | 1 |
| clay | | 29 | 30 | 1 |
| cobbles, sand, silt + clay | | 30 | 31 | 1 |
| pea gravel, clay + sand | | 31 | 36 | 5 |

Date started 5/05, 1994
Date completed 5/05, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

| G.P.M. | Draw Down (Feet Below Static) | Time (Hours) |
|---|---|---|
| | | |

8. WELL CONSTRUCTION
Depth Drilled 36 Feet Depth Cased 36 Feet

HOLE DIAMETER (BIT SIZE)

| Inches | From (Feet) | To (Feet) |
|---|---|---|
| 6.5 | 0 | 25 |
| | | |
| | | |

CASING SCHEDULE

| Size O.D. (Inches) | Weight/Ft. (Pounds) | Wall Thickness (Inches) | From (Feet) | To (Feet) |
|---|---|---|---|---|
| 2" | sched 40 | PVC | 0 | 25 |
| | | | | |
| | | | | |

Perforations:
Type perforation factory
Size perforation 0.02 inches
From 18 feet to 25 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☑ Yes ☐ No
Depth of Seal 5 feet
Placement Method: ☐ Pumped ☑ Poured
Seal Type: ☑ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☑ Yes ☐ No #16 sand
From 6 feet to 25 feet

9. WATER LEVEL
Static water level 14 feet below land surface
Artesian flow NO G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Kathryn C Kilroy
Contractor
Address 333 W. Nye Ln
Contractor
Carson City NV 89706
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller EP 1519
Signed
By driller performing actual drilling on site or contractor
Date 5/05/94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627