

STATE OF NEVADA
 DIVISION OF WATER RESOURCES
WELL DRILLER'S REPORT

OFFICE USE ONLY
 Log No. 46068
 Permit No. _____
 Basin 162

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 13538

1. OWNER Kenneth Willett (B+K) ADDRESS AT WELL LOCATION Lot # 43
 MAILING ADDRESS 12300 W. Tropicana Ave. Las Vegas, NV 89109 Windsong St. Pahrump, NV 89041
 2. LOCATION N-E 1/4, N-W 1/4 Sec. 13 T. 20 S N/S R. 53 E E Nye County
 PERMIT NO. 28-702-05 Parcel No. _____ Subdivision Name Charleston Park

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sandy Soil		0	5	5
Decomposed Caliche		5	10	5
Grey Clay		10	17	7
Brown Clay		17	23	6
Grey Clay		23	48	25
Green Clay		48	70	32
Grey Clay		70	120	50
Brown Clay		120	140	20

8. WELL CONSTRUCTION
 Depth Drilled 140 Feet Depth Cased 140 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 140
12 Inches 0 Feet 140 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8</u>	<u>17</u>	<u>.188</u>	<u>0</u>	<u>140</u>

 Perforations:
 Type perforation Factory
 Size perforation 3 X 16 X 4'
 From _____ feet to _____ feet
 From 120 feet to 140 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50' Neat Cement
 Placement Method: Pumped Concrete Grout
 Poured
 Gravel Packed: Yes No
 From 50' feet to 140' feet

RECEIVED

OCT 10 1994

Div. of Water Resources
 Branch Office - Las Vegas, NV

Date started 09-19-94 19____
 Date completed 09-21-94 19____

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	<u>30</u>	<u>4</u>	<u>1/2 hr.</u>

9. WATER LEVEL
 Static water level 53 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature COLD Quality GOOD

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Harry's Water Well Service Contractor
 Address P.O. Box 3392 Contractor
Pahrump, NV 89041
 Nevada contractor's license number issued by the State Contractor's Board 0035901
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1916
 Signed Harry H. Clendenen
 By driller performing actual drilling on site or contractor
 Date 10-7-94