

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT
 Please complete this form in its entirety in
 accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____
 ADDRESS AT WELL LOCATION 604 W. Musser Street
Carson City, Nevada

1. OWNER Carson City School District ADDRESS AT WELL LOCATION 604 W. Musser Street
 MAILING ADDRESS P. O. Box 603
Carson City, Nevada 89702

2. LOCATION SE 1/4 NE 1/4 Sec 18 T 15 (N/8 R 20 E Carson City County
 PERMIT NO. M/O-789 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other Auger

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
6 inches Concrete		0.0	0.5	0.5
DARK BROWN SILTY SAND (SM) with minor gravel, loose, moist		0.5	2.5	2.0
DARK BROWN CLAYEY SAND (SC) with minor gravel, loose, moist		2.5	18.0	15.5
Stratified with silty sand and clayey gravel below 10.0 feet				
BROWN SAND (SP) with silt and gravel, dense, saturated		18.0	23.5	?
Water level		18.0	18.0	23.5

8. WELL CONSTRUCTION
 Depth Drilled 23.5 Feet Depth Cased 23.5 Feet
 HOLE DIAMETER (BIT SIZE)
 From 10.0 Inches To 23.5 Feet
 _____ Inches _____ Feet
 _____ Inches _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.50	2.0	0.237	0.0	23.5

Perforations:
 Type perforation Circumslot
 Size perforation 0.02
 From 8.5 feet to 23.5 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 0.0 to 5.0 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 5.0 feet to 23.5 feet

9. WATER LEVEL
 Static water level 18.0 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cold °F Quality clean

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Pezonella Associates, Inc. Contractor
 Address 520 Edison Way Contractor
Sparks, Nevada 89502
 Nevada contractor's license number issued by the State Contractor's Board _____
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 4186
 Signed Kenneth M. Pezonella
 By driller performing actual drilling on site or contractor
 Date 6/23/94

Date started May 8, 1994
 Date completed May 8, 1994

7. WELL TEST DATA

TEST METHOD	<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input type="checkbox"/> Air Lift	Draw Down (Feet Below Static)	Time (Hours)
<u>JUL 1 1994</u>	<u>G.P.M.</u>		

JUN 31 1994
 STATE ENGINEERS OF NV
 PEZONELLA ASSOCIATES, INC.
 STATE ENGINEERS OF NV