WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46111
Permit No.
Basin 212

NOTICE OF INTENT NO. 13741

1. OWNER LV CONVENTION & VISITORS AUTHORITY
MAILING ADDRESS 3150 PARADISE ROAD
LAS VEGAS NV 89109

ADDRESS AT WELL LOCATION PARKING LOT OF THE SOUTH HALL OF THE CONVENTION CENTER

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MD-2478 (Issued by Water Resources) 162-10-401-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE B-105
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	1.5	1.5
SANDY CLAY		1.5	7	5.5
CALICHE		7	8.5	1.5
SANDY CLAY		8.5	17	8.5
CLAYEY GRAVEL		17	22.5	5.5
CALICHE		22.5	25.5	3
SANDY CLAY		25.5	26	0.5
CALICHE		26	29	3
SANDY CLAY		29	40	11
CALICHE		40	43	3
SANDY CLAY		43	50	7

RECEIVED
AUG 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

TEMPORARY WELL

Date started AUGUST 4, 1994
Date completed AUGUST 4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

8. WELL CONSTRUCTION
Depth Drilled 50 Feet Depth Cased 38 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
6 Inches	0 Feet	50 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	38

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020"
From 18 feet to 38 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☐ Yes ☒ No
Depth of Seal 13-16' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☐ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 16 feet to 38 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name DON WILSON
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103

Nevada contractor's license number issued by the State Contractor's Board

Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1589

Signed Don Wilson
By driller performing actual drilling on site or contractor
Date AUGUST 9, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627