WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46112
Permit No.
Basin 212

NOTICE OF INTENT NO. 13741

1. OWNER LV CONVENTION & VISITORS AUTHORITY
MAILING ADDRESS 3150 PARADISE RD LAS VEGAS NV 89109
ADDRESS AT WELL LOCATION DESERT INN ROAD BETWEEN PARADISE AND SWENSON

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 21 N(S) R. 61 E. CLARK County
PERMIT NO. M0-2478 (Issued by Water Resources) 162-10-401-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE B-110
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2	2
GYPSIFEROUS SAND		2	3	1
CALICHE		3	4.5	1.5
SANDY CLAY		4.5	11	6.5
SILTY SAND		11	14	3
WELL GRADED SAND		14	15.5	1.5
SILTY SAND		15.5	17	1.5
SANDY CLAY		17	23	6
SANDY SILT		23	24	1
SANDY CLAY		24	31	7
SILTY SAND		31	34	3
GRAVELLY CLAY		34	37	3
CLAYEY GRAVEL		37	38	1
GRAVELLY CLAY		38	39	1
CALICHE		39	41	2
CLAYEY GRAVEL		41	42	1
GRAVELLY CLAY		42	44	2
CEMENTED SAND/GRV		44	45	1
CLAY		45	51	6
CLAYEY GRAVEL		51	53	2
CEMENTED SAND/GRV		53	56	3
SANDY CLAY		56	60	4
CLAYEY GRAVEL		60	62	2
SANDY CLAY		62	80	18

Date started AUGUST 5, 1994
Date completed AUGUST 5, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

	From	To
8 Inches	0 Feet	80 Feet
Inches	Feet	Feet
Inches	Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
2.375	0.64	0.154	0	65

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 35 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-26'/26-31' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 31 feet to 65 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 4670 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed [signature]
By driller performing actual drilling on site or contractor
Date AUGUST 9, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627