WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

in Book

OFFICE USE ONLY
Log No. 46113
Permit No.
Basin 212

NOTICE OF INTENT NO. 13741

1. OWNER LAS VEGAS CONVENTION & VISITORS
MAILING ADDRESS AUTHORITY 3150 PARADISE
LAS VEGAS NV 89109

ADDRESS AT WELL LOCATION IN PARKING LOT OF THE SOUTH HALL OF THE CONVENTION CENTER

2. LOCATION NE ¼ NW ¼ Sec. 15 T. 21 N/S R. 61 E. CLARK County
PERMIT NO. MD-2478 (Issued by Water Resources) 162-10-401-001 (Parcel No.) Subdivision Name

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE B-104
☐ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☒ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☐ Rotary ☐ RVC
☐ Air ☒ Other AUGER

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
ASPHALT/FILL		0	2	2
SILTY SAND		2	4	2
SANDY CLAY		4	6	2
CALICHE		6	7	1
SANDY CLAY		7	8	1
CALICHE		8	8.5	0.5
SANDY CLAY		8.5	10	1.5
CLAYEY GRAVEL		10	11	1
SANDY CLAY		11	16	5
SILTY SAND		16	17	1
CLAYEY GRAVEL		17	18	1
SANDY CLAY		18	20	2
CEMENTED SAND/GRAV		20	21	1
CLAYEY GRAVEL		21	22.5	1.5
SILTY SAND		22.5	25	2.5
SANDY CLAY		25	27	2
CLAYEY SAND		27	29	2
SANDY CLAY		29	32	3
SANDY GRAVEL		32	34	2
GRAVELLY CLAY		34	37	3
CEMENTED SAND/GRAV		37	40.5	3.5
SANDY TO GRAVELLY CLAY		40.5	48	7.5
CEMENTED SAND/GRAV		48	50	2
SANDY CLAY		50	54	4
CALICHE		54	56.5	2.5
SANDY CLAY		56.5	80	23.5

Date started AUGUST 4, 1994
Date completed AUGUST 4, 1994

7. WELL TEST DATA
TEST METHOD: ☐ Bailer ☐ Pump ☐ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)

RECEIVED
AUG 10 1994
Div. of Water Resources
Branch Office - Las Vegas, NV

8. WELL CONSTRUCTION
Depth Drilled 80 Feet Depth Cased 65 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
8 Inches		0 Feet	80 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
4.5	1.9	0.237	0	65

Perforations:
Type perforation FACTORY SLOT
Size perforation 0.020
From 20 feet to 65 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 0-14'/14-16' BENTONITE
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 16 feet to 65 feet

9. WATER LEVEL
Static water level feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature °F Quality

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name THOMAS HIGH
Contractor
Address 4070 SO. POLARIS AVE
Contractor
LAS VEGAS NV 89103
Nevada contractor's license number issued by the State Contractor's Board
Nevada driller's license number issued by the Division of Water Resources, the on-site driller M1869
Signed Tom High
By driller performing actual drilling on site or contractor
Date AUG 9, 1994

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627